

102071	25-06-2023	10:34:00	First Draw	BF	1 BF	0.0002	No		
102071	25-06-2023	10:35:00	First Draw	DW	1 DW	0.00186	No		
102071	25-06-2023	10:36:00	First Draw	CF	1 CF	0.00763	Yes	3C	Signage posted (Restricted use - Handwash Only)
102071	25-06-2023	10:37:00	First Draw	DW	2 DW	0.00175	No		
102071	25-06-2023	10:38:00	First Draw	CF	2 CF	0.00174	No		
102071	25-06-2023	10:39:00	First Draw	DW	3 DW	0.0014	No		
102071	25-06-2023	10:40:00	First Draw	CF	3 CF	0.0107	Yes	3C	Signage posted (Restricted use - Handwash Only)
102071	25-06-2023	10:41:00	First Draw	DW	4 DW	0.00103	No		
102071	25-06-2023	10:42:00	First Draw	CF	4 CF	0.00122	No		
102071	25-06-2023	10:43:00	First Draw	CF	5 CF	0.00282	No		
102071	25-06-2023	10:44:00	First Draw	BF	2 BF	0.0002	No		
102071	25-06-2023	10:45:00	First Draw	CF	6 CF	0.00703	Yes	3C	Signage posted (Restricted use - Handwash Only)
102071	25-06-2023	10:46:00	First Draw	KC	5 KC	0.00095	No		
102071	25-06-2023	10:47:00	First Draw	CF	7 CF	0.00719	No		
102071	25-06-2023	10:48:00	First Draw	CF	8 CF	0.00251	No		
102071	25-06-2023	10:49:00	First Draw	DW	6 DW	0.00043	No		
102071	25-06-2023	10:50:00	First Draw	BF	3 BF	0.0002	No		
102071	25-06-2023	10:51:00	First Draw	CF	9 CF	3.47	Yes	3C	Signage posted (Restricted use - Handwash Only)
102071	25-06-2023	10:52:00	First Draw	CF	9 DW	0.00059	No		
102071	25-06-2023	10:53:00	First Draw	CF	10 CF	0.00609	Yes	3C	Signage posted (Restricted use - Handwash Only)
102071	25-06-2023	10:54:00	First Draw	CF	11 CF	0.00942	Yes	3C	Signage posted (Restricted use - Handwash Only)
102071	25-06-2023	10:55:00	First Draw	DW	11 DW	0.00063	No		
102071	25-06-2023	10:56:00	First Draw	CF	12 CF	0.00281	No		
102071	25-06-2023	10:57:00	First Draw	DW	12 DW	0.00051	No		
102071	25-06-2023	10:58:00	First Draw	CF	13 CF	0.00494	No		
102071	25-06-2023	10:59:00	First Draw	DW	13 DW	0.00041	No		
102071	25-06-2023	11:00:00	First Draw	KC	6 KC	0.00291	No		
102071	25-06-2023	11:01:00	First Draw	CF	14 CF	0.00492	No		
Unsworth Elementary									
102076	18-06-2023	07:32:00	First Draw	KC	26 KC	0.00135	No		
102076	18-06-2023	07:40:00	First Draw	KC	PAC KC	0.00529	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced.
102076	10-12-2023	15:00:00	First Draw	KC	PAC KC	0.00487	No		Faucet and supply lines Replaced (Re-Test Results-Pass)
102076	10-12-2023	15:05:00	Flushed	KC	PAC KC	0.0002	No		Faucet and supply lines Replaced (Re-Test 1 min Results-Pass)
102076	18-06-2023	07:45:00	First Draw	BF	BF 1	0.0002	No		
102076	18-06-2023	07:50:00	First Draw	BF	BF 2	0.0002	No		
102076	18-06-2023	07:55:00	First Draw	DW	12 DW	0.00338	No		
102076	18-06-2023	08:00:00	First Draw	CF	12 CF	0.0026	No		
102076	18-06-2023	08:05:00	First Draw	DW	14 DW	0.0105	Yes	3C	Bubbler removed - Signage posted (Restricted use - Handwash Only)
102076	18-06-2023	08:10:00	First Draw	CF	14 CF	0.00149	No		
102076	18-06-2023	08:15:00	First Draw	KC	11 KC	0.00286	No		
102076	18-06-2023	08:25:00	First Draw	CF	11 CF	0.00341	No		
102076	18-06-2023	08:30:00	First Draw	DW	13 DW	0.0114	Yes	3C	Bubbler removed - Signage posted (Restricted use - Handwash Only)
102076	18-06-2023	08:35:00	First Draw	CF	13 CF	0.00113	No		
102076	18-06-2023	08:40:00	First Draw	CF	16 CF	0.00482	No		
102076	18-06-2023	08:45:00	First Draw	CF	15 CF	0.00306	No		
102076	18-06-2023	08:50:00	First Draw	KC	18 KC	0.00516	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced.
102076	10-12-2023	15:10:00	First Draw	KC	18 KC	0.00096	No		Faucet and supply lines Replaced (Re-Test Results-Pass)
102076	10-12-2023	15:15:00	Flushed	KC	18 KC	0.0002	No		Faucet and supply lines Replaced (Re-Test 1 min Results-Pass)
102076	18-06-2023	08:52:00	First Draw	DW	18 DW	0.00231	No		
102076	18-06-2023	08:52:00	First Draw	CF	18 CF	0.00092	No		
102076	18-06-2023	08:55:00	First Draw	DW	20 DW	0.00251	No		
102076	18-06-2023	08:56:00	First Draw	CF	20 CF	0.00133	No		
102076	18-06-2023	08:57:00	First Draw	DW	19 DW	0.00461	No		
102076	18-06-2023	08:59:00	First Draw	CF	19 CF	0.002	No		
102076	18-06-2023	09:00:00	First Draw	DW	17 DW	0.00283	No		
102076	18-06-2023	09:02:00	First Draw	CF	17 CF	0.00602	Yes	3C	Bubbler removed - Signage posted (Restricted use - Handwash Only)
102076	18-06-2023	09:05:00	First Draw	DW	10 DW	0.00195	No		
102076	18-06-2023	09:06:00	First Draw	CF	10 CF	0.00105	No		
102076	18-06-2023	09:07:00	First Draw	DW	9 DW	0.00133	No		
102076	18-06-2023	09:09:00	First Draw	CF	9 CF	0.00745	Yes	3C	Bubbler removed - Signage posted (Restricted use - Handwash Only)
102076	18-06-2023	09:10:00	First Draw	CF	7 CF	0.00807	Yes	3C	Bubbler removed - Signage posted (Restricted use - Handwash Only)
102076	18-06-2023	09:12:00	First Draw	DW	8 DW	0.00121	No		
102076	18-06-2023	09:15:00	First Draw	CF	8 CF	0.00116	Yes	3C	Bubbler removed - Signage posted (Restricted use - Handwash Only)
102076	18-06-2023	09:17:00	First Draw	DW	5 DW	0.00607	Yes	3C	Bubbler removed - Signage posted (Restricted use - Handwash Only)
102076	18-06-2023	09:17:00	First Draw	CF	5 CF	0.00301	No		
102076	18-06-2023	09:20:00	First Draw	DW	3 DW	0.00551	Yes	3C	Bubbler removed - Signage posted (Restricted use - Handwash Only)
102076	18-06-2023	09:20:00	First Draw	CF	3 CF	0.00285	No		
102076	18-06-2023	09:22:00	First Draw	DW	1 DW	0.00804	Yes	3C	Bubbler removed - Signage posted (Restricted use - Handwash Only)
102076	18-06-2023	09:22:00	First Draw	CF	1 CF	0.00061	No		
102076	18-06-2023	09:24:00	First Draw	CF	6 CF	0.00479	Yes	3C	Bubbler removed - Signage posted (Restricted use - Handwash Only)
102076	18-06-2023	09:27:00	First Draw	DW	4 DW	0.00097	No		
102076	18-06-2023	09:27:00	First Draw	CF	4 CF	0.00287	Yes	3C	Bubbler removed - Signage posted (Restricted use - Handwash Only)
120754	18-06-2023	09:37:00	First Draw	KC	ANX KC	0.0116	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced.
120754	10-12-2023	15:20:00	First Draw	KC	ANX KC	0.00255	No		Faucet and supply lines Replaced (Re-Test Results-Pass)
120754	10-12-2023	15:25:00	Flushed	KC	ANX KC	0.00036	No		Faucet and supply lines Replaced (Re-Test 1 min Results-Pass)
120754	18-06-2023	09:40:00	First Draw	DW	W DW	0.00083	No		
120754	18-06-2023	09:30:00	First Draw	CF	2 CF additional	0.0035	No		
120754	10-12-2023	15:30:00	First Draw	BF	ANX-BF	0.0002	No		
Chilliwack Middle									
101970	17-09-2023	11:15:00	First Draw	KC	KC 119	0.00076	No		
101970	17-09-2023	11:20:00	First Draw	KC	KC Staff	0.00264	No		
101970	17-09-2023	11:25:00	First Draw	BF	BF 1	0.0002	No		
101970	17-09-2023	11:30:00	First Draw	KC	KC 1	0.00434	No		
101970	17-09-2023	11:35:00	First Draw	KC	KC 2	0.00456	No		
101970	17-09-2023	12:00:00	First Draw	BF	BF 2	0.0002	No		
101970	17-09-2023	13:00:00	First Draw	BF	BF 3	0.0002	No		
101970	17-09-2023	13:05:00	First Draw	KC	KC F1	0.0049	No		
101970	17-09-2023	13:10:00	First Draw	KC	KC F2	0.0094	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced.
101970	10-12-2023	11:00:00	First Draw	KC	KC F2	0.00021	No		Faucet and supply lines Replaced (Re-Test Results-Pass)
101970	10-12-2023	11:05:00	Flushed	KC	KC F2	0.00049	No		Faucet and supply lines Replaced (Re-Test 1 min Results-Pass)
101970	17-09-2023	13:15:00	First Draw	KC	KC F3	0.00284	No		
101970	17-09-2023	13:20:00	First Draw	KC	KC F4	0.00233	No		
101970	17-09-2023	13:25:00	First Draw	KC	KC F5	0.00719	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced.
101970	10-12-2023	11:10:00	First Draw	KC	KC F5	0.00036	No		Faucet and supply lines Replaced (Re-Test Results-Pass)
101970	10-12-2023	11:15:00	Flushed	KC	KC F5	0.0002	No		Faucet and supply lines Replaced (Re-Test 1 min Results-Pass)
101970	17-09-2023	13:30:00	First Draw	KC	KC F6	0.00241	No		
101970	17-09-2023	13:35:00	First Draw	KC	KC F7	0.0039	No		
101970	17-09-2023	13:40:00	First Draw	KC	KC 226	0.00458	No		
101970	17-09-2023	13:45:00	First Draw	BF	BF4	0.0002	No		
QWG									
300258	15-10-2023	08:30:00	First Draw	KC	KC 165	0.00091	No		
300258	15-10-2023	09:30:00	First Draw	BF	BF 169	0.0002	No		
300258	15-10-2023	09:35:00	First Draw	KC	KC LIB	0.00229	No		
300258	15-10-2023	09:40:00	First Draw	KC	KC 138	0.00038	No		
300258	15-10-2023	09:45:00	First Draw	KC	KC 103-1	0.00043	No		
300258	15-10-2023	09:50:00	First Draw	KC	KC 103-2	0.0135	Yes	2B	Signage posted (Flush Notice)
300258	13-03-2024	07:00:00	Flushed	KC	KC 103-2	0.00067	No		
300258	15-10-2023	09:55:00	First Draw	BF	BF 109	0.0002	No		
300258	15-10-2023	10:30:00	First Draw	KC	KC 114-1	0.00109	No		
300258	15-10-2023	10:35:00	First Draw	KC	KC 114-2	0.00007	No		

300258	15-10-2023	10:40:00	First Draw	KC	KC 114-3	0.00134	No		
300258	15-10-2023	10:45:00	First Draw	KC	KC 114-4	0.003	No		
300258	15-10-2023	10:50:00	First Draw	KC	KC 114-5	0.0012	No		
300258	15-10-2023	10:55:00	First Draw	KC	KC 114-6	0.00177	No		
300258	15-10-2023	11:00:00	First Draw	KC	KC 114-7	0.00479	No		
300258	15-10-2023	11:05:00	First Draw	KC	KC 132-1	0.00652	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced.
300258	10-25-2023	13:20:00	First Draw	KC	KC 132-1	0.00078	No		Faucet and supply lines Replaced (Re-Test Results-Pass)
300258	10-25-2023	13:25:00	Flushed	KC	KC 132-1	0.0002	No		Faucet and supply lines Replaced (Re-Test 1 min Results-Pass)
300258	15-10-2023	11:10:00	First Draw	KC	KC 132-2	0.00095	No		
300258	15-10-2023	11:15:00	First Draw	KC	KC 132-3	0.00165	No		
300258	15-10-2023	11:20:00	First Draw	KC	KC 132-4	0.0011	No		
300258	15-10-2023	11:25:00	First Draw	KC	KC 132-5	0.00975	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced.
300258	10-25-2023	13:30:00	First Draw	KC	KC 132-5	0.00031	No		Faucet and supply lines Replaced (Re-Test Results-Pass)
300258	10-25-2023	13:35:00	Flushed	KC	KC 132-5	0.00034	No		Faucet and supply lines Replaced (Re-Test 1 min Results-Pass)
300258	15-10-2023	11:30:00	First Draw	KC	KC 132-6	0.00259	No		
300258	15-10-2023	11:35:00	First Draw	KC	KC 132-7	0.00422	No		
300258	15-10-2023	11:40:00	First Draw	KC	KC 132-B	0.00379	No		
300258	15-10-2023	11:45:00	First Draw	KC	KC 133	0.00027	No		
300258	15-10-2023	11:50:00	First Draw	BF	BF 50	0.0002	No		
300258	15-10-2023	11:55:00	First Draw	DW	DW 146	0.00051	No		
300258	15-10-2023	12:00:00	First Draw	DW	DW 128	0.00079	No		
300258	15-10-2023	12:05:00	First Draw	KC	KC 124	0.00354	No		
300258	15-10-2023	12:10:00	First Draw	BF	BF 123	0.0002	No		
300258	15-10-2023	12:15:00	First Draw	KI	KI 123	0.0002	No		
300258	15-10-2023	12:20:00	First Draw	CF	CF 107	0.00127	No		
300258	15-10-2023	12:45:00	First Draw	KC	KC 1020-1	0.00103	No		
300258	15-10-2023	12:50:00	First Draw	KC	KC 1020-2	0.00348	No		
300258	15-10-2023	12:55:00	First Draw	KC	KC 1020-3	0.00233	No		
300258	15-10-2023	13:00:00	First Draw	KC	KC 1020-4	0.00107	No		
300258	15-10-2023	13:05:00	First Draw	KC	KC 1020-5	0.00208	No		
300258	15-10-2023	13:10:00	First Draw	KC	KC 1020-6	0.00105	No		
300258	15-10-2023	13:15:00	First Draw	KC	KC 1020-T	0.00138	No		
300258	15-10-2023	13:20:00	First Draw	BF	BF 1005	0.0002	No		
300258	15-10-2023	14:20:00	First Draw	KC	KC 203	0.00047	No		
300258	15-10-2023	15:00:00	First Draw	BF	BF 241	0.0002	No		
300258	15-10-2023	15:15:00	First Draw	BF	BF 212	0.0002	No		
300258	15-10-2023	15:45:00	First Draw	DW	DW 221	0.00338	No		
Imagine High									
300798	10-09-2023	08:00:00	First Draw	BF	BF 145	0.0002	No		
300798	10-09-2023	08:05:00	First Draw	BF	BF 197	0.0002	No		
300798	10-09-2023	08:10:00	First Draw	KC	KC1	0.00104	No		
300798	10-09-2023	08:15:00	First Draw	KC	KC2	0.00066	No		
300798	10-09-2023	08:20:00	First Draw	KC	KC3	0.00035	No		
300798	10-09-2023	08:25:00	First Draw	KC	KC4	0.00049	No		
300798	10-09-2023	08:30:00	First Draw	KC	KC5	0.00052	No		
300798	10-09-2023	08:35:00	First Draw	KC	KC6	0.0019	No		
300798	10-09-2023	08:40:00	First Draw	KC	KC 166	0.0002	No		
300798	10-09-2023	08:45:00	First Draw	KC	KC Pot	0.0665	Yes	2B	Signage posted (Flush Notice)
300798	13-03-2024	07:05:00	Flushed	KC	KC Pot	0.00122	No		
300798	10-09-2023	08:50:00	First Draw	KC	KC7	0.00363	No		
300798	10-09-2023	08:55:00	First Draw	KC	KC8	0.00091	No		
300798	10-09-2023	09:00:00	First Draw	KC	KC9	0.00118	No		
300798	10-09-2023	09:05:00	First Draw	BF	BF 118	0.0002	No		
300798	10-09-2023	09:10:00	First Draw	NS	NS 111	0.00187	No		
300798	10-09-2023	09:15:00	First Draw	BF	BF 105	0.0002	No		
300798	10-09-2023	09:20:00	First Draw	KC	KC Store	0.00111	No		
300798	10-09-2023	09:25:00	First Draw	KC	KC 172	0.0164	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced.
300798	10-12-2023	09:40:00	First Draw	KC	KC 172	0.00046	No		Faucet and supply lines Replaced (Re-Test Results-Pass)
300798	10-12-2023	09:45:00	Flushed	KC	KC 172	0.00024	No		Faucet and supply lines Replaced (Re-Test 1 min Results-Pass)
300798	10-09-2023	09:30:00	First Draw	BF	BF 172	0.0002	No		
300798	10-09-2023	10:00:00	First Draw	KC	KC 201	0.0164	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced.
300798	10-12-2023	09:30:00	First Draw	KC	KC 201	0.00062	No		Faucet and supply lines Replaced (Re-Test Results-Pass)
300798	10-12-2023	09:55:00	Flushed	KC	KC 201	0.0003	No		Faucet and supply lines Replaced (Re-Test 1 min Results-Pass)
300798	10-09-2023	10:05:00	First Draw	BF	BF 213	0.0002	No		
Kwiyogel Secondary									
101980	17-09-2023	08:00:00	First Draw	BF	BF1	0.0006	No		
101980	17-09-2023	08:05:00	First Draw	KC	KC1	0.00092	No		
101980	17-09-2023	08:10:00	First Draw	KC	KC2	0.00079	No		
101980	17-09-2023	08:15:00	First Draw	KC	KC3	0.00086	No		
101980	17-09-2023	08:20:00	First Draw	KC	KC4	0.00239	No		
101980	17-09-2023	08:25:00	First Draw	BF	BF2	0.0002	No		
101980	17-09-2023	08:30:00	First Draw	KC	KC Staff	0.0126	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced.
101980	10-12-2023	09:00:00	First Draw	KC	KC Staff	0.0018	No		Faucet and supply lines Replaced (Re-Test Results-Pass)
101980	10-12-2023	09:05:00	Flushed	KC	KC Staff	0.00062	No		Faucet and supply lines Replaced (Re-Test 1 min Results-Pass)
101980	17-09-2023	08:35:00	First Draw	KC	KC5	0.00554	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced.
101980	10-12-2023	09:15:00	First Draw	KC	Kc5	0.00284	No		Faucet and supply lines Replaced (Re-Test Results-Pass)
101980	10-12-2023	09:15:00	Flushed	KC	Kc5	0.00062	No		Faucet and supply lines Replaced (Re-Test 1 min Results-Pass)
101980	17-09-2023	08:40:00	First Draw	BF	BF Fridge (misspell)	0.0002	No		
LSD (Learning Services)									
102078	10-09-2023	14:00:00	First Draw	KC	KC1	0.00614	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced.
102078	10-12-2023	12:30:00	First Draw	KC	KC1	0.00359	No		Faucet and supply lines Replaced (Re-Test Results-Pass)
102078	10-12-2023	12:35:00	Flushed	KC	KC1	0.0002	No		Faucet and supply lines Replaced (Re-Test 1 min Results-Pass)
102078	10-09-2023	14:10:00	First Draw	BF	BF1	0.0002	No		
102078	10-09-2023	14:15:00	First Draw	KC	KC2	0.00215	No		
Stolo									
NA	17-09-2023	07:30:00	First Draw	KC	KC Staff	0.00411	No		
Sardis Secondary School									
102037	29-10-2023	08:00:00	First Draw	KC	KC108	0.00649	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced.
102037	10-12-2023	07:00:00	First Draw	KC	KC108	0.00019	No		Faucet and supply lines Replaced (Re-Test Results-Pass)
102037	10-12-2023	07:05:00	Flushed	KC	KC108	0.00091	No		Faucet and supply lines Replaced (Re-Test 1 min Results-Pass)
102037	29-10-2023	08:05:00	First Draw	NS	NS1	0.0101	Yes	2B	Signage posted (Flush Notice)
102037	16-03-2024	08:25:00	Flushed	NS	NS1	0.00025	No		
102037	29-10-2023	08:10:00	First Draw	KI	KI1	0.0002	No		
102037	29-10-2023	08:15:00	First Draw	BM	BM1	0.0002	No		
102037	29-10-2023	08:20:00	First Draw	KC	KC102-1	0.00273	No		
102037	29-10-2023	08:25:00	First Draw	KC	KC102-2	0.00078	No		
102037	29-10-2023	08:30:00	First Draw	KC	KC102-3	0.00417	No		
102037	29-10-2023	08:35:00	First Draw	KC	KC102-4	0.00129	No		
102037	29-10-2023	08:40:00	First Draw	DW	DW1	0.00155	No		
102037	29-10-2023	09:00:00	First Draw	BF	BF1	0.00077	No		
102037	29-10-2023	09:05:00	First Draw	DW	DW2	0.00233	No		
102037	29-10-2023	09:40:00	First Draw	DW	DW3	0.0071	Yes	3C	Bubbler removed - Signage posted (Restricted use - Handwash Only)
102037	29-10-2023	09:45:00	First Draw	DW	DW4	0.00114	No		

