

School Identifier	Testing information						Result		Mitigation Strategy Selected	Public Communication Plan
Ministry Asset Number	Test Date (dd-mm-yyyy)	Time of test (24hr clock)	Outlet ID (optional)	Sample Type	Fixture Type	Fixture Location Description	Lead Result (mg/L)	Exceeds Maximum Acceptable Concentration		
123456	11-12-2022	07:45:00	211_1_104_CF	Flushed	CF	Classroom Faucet (CF) in room 104, first floor, facility 211.	0.0043	No	2A	Post signage near the fixture to run the water at least one minute before drinking or using water for food preparation until replacement. Retest fixture following replacement.
Chilliwack Secondary										
300675	25-01-2025	07:00:00		First Draw	KC	KC-1A (Rm 1154)	0.00237	No		
300675	25-01-2025	07:05:00		Flushed	KC	KC-1B (Rm-1154)	0.00165	No		
300675	25-01-2025	07:10:00		First Draw	BM	BM-1 (Rm-1154)	0.0002	No		
300675	25-01-2025	07:15:00		First Draw	KI	KI-1 (Rm-1154)	0.00149	No		
300675	25-01-2025	07:20:00		First Draw	NS	NS-1A (Rm1100J)	0.0009	No		
300675	25-01-2025	07:25:00		Flushed	NS	NS-1B (Rm1100J)	0.0004	No		
300675	25-01-2025	07:30:00		First Draw	KI	KI-2 (Rm1100J)	0.00065	No		
300675	25-01-2025	07:35:00		First Draw	BF	BF-1 (1st Floor Hall office)	0.0002	No		
300675	25-01-2025	07:40:00		First Draw	CF	CF-1A (Rm 1164)	0.0011	No		
300675	25-01-2025	07:45:00		Flushed	CF	CF-1B (Rm 1164)	0.0002	No		
300675	25-01-2025	07:50:00		First Draw	EC	EC-1A (Rm 1166)	0.0012	No		
300675	25-01-2025	07:55:00		Flushed	EC	EC-1B (Rm 1166)	0.00033	No		
300675	25-01-2025	08:00:00		First Draw	EC	EC-2A (Rm 1170)	0.0013	No		
300675	25-01-2025	08:05:00		Flushed	EC	EC-2B (Rm 1170)	0.0002	No		
300675	25-01-2025	08:10:00		First Draw	EC	EC-3-1A (Rm 1172)	0.00055	No		
300675	25-01-2025	08:15:00		Flushed	EC	EC-3-1B (Rm 1172)	0.00052	No		
300675	25-01-2025	08:20:00		First Draw	EC	EC-3-2A (Rm 1172)	0.00126	No		
300675	25-01-2025	08:25:00		Flushed	EC	EC-3-2B (Rm 1172)	0.00035	No		
300675	25-01-2025	08:30:00		First Draw	EC	EC-3-3A (Rm 1172)	0.00155	No		
300675	25-01-2025	08:35:00		Flushed	EC	EC-3-3B (Rm 1172)	0.00034	No		
300675	25-01-2025	08:40:00		First Draw	EC	EC-3-4A (Rm 1172)	0.00579	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
300675	25-01-2025	08:45:00		Flushed	EC	EC-3-4B (Rm 1172)	0.00042	No		
300675	23-02-2025	12:00:00		First Draw	EC	EC-3-4A (Rm 1172)	0.00149	No		RE-TEST results
300675	25-01-2025	08:45:00		Flushed	EC	EC-3-4B (Rm 1172)	0.00042	No		
300675	25-01-2025	08:50:00		First Draw	EC	EC-3-5A (Rm 1172)	0.00266	No		
300675	25-01-2025	08:55:00		Flushed	EC	EC-3-5B (Rm 1172)	0.00022	No		
300675	25-01-2025	09:00:00		First Draw	EC	EC-3-6A (Rm 1172)	0.00115	No		
300675	25-01-2025	09:05:00		Flushed	EC	EC-3-6B (Rm 1172)	0.00056	No		
300675	25-01-2025	09:10:00		First Draw	EC	EC-3-7A (Rm 1172)	0.00404	No		
300675	25-01-2025	09:15:00		Flushed	EC	EC-3-7B (Rm 1172)	0.0014	No		
300675	25-01-2025	09:20:00		First Draw	EC	EC-3-8A (Rm 1172)	0.00395	No		
300675	25-01-2025	09:25:00		Flushed	EC	EC-3-8B (Rm 1172)	0.0003	No		
300675	25-01-2025	09:30:00		First Draw	BF	BF-2 (1st Floor Hall small gym)	0.0002	No		
300675	25-01-2025	09:35:00		First Draw	BF	BF-3 (1st Floor Hall North big gym)	0.0002	No		
300675	25-01-2025	09:40:00		First Draw	BF	BF-4 (1st Floor Hall Multi purpose)	0.0002	No		
300675	25-01-2025	09:45:00		First Draw	BF	BF-5 (1st Floor Hall Art wing)	0.0002	No		
300675	25-01-2025	09:50:00		First Draw	KC	KC-2A (Rm 1112)	0.00296	No		
300675	25-01-2025	09:55:00		Flushed	KC	KC-2B (Rm 1152)	0.00097	No		
300675	25-01-2025	10:00:00		First Draw	BM	BM-2 (Rm 1152)	0.00031	No		
300675	25-01-2025	10:05:00		First Draw	BM	BM-3 (Rm 1152)	0.0002	No		
300675	25-01-2025	10:10:00		First Draw	KC	KC-3A (Rm 1108)	0.00107	No		
300675	25-01-2025	10:15:00		Flushed	KC	KC-3B (Rm 1108)	0.00118	No		
300675	25-01-2025	10:20:00		First Draw	KC	KC-4A (Rm 1104)	0.0007	No		
300675	25-01-2025	10:25:00		Flushed	KC	KC-4B (Rm 1104)	0.0012	No		
300675	25-01-2025	10:30:00		First Draw	OT	OT-1A (Rm-1109)	0.681	Yes	3C	Fixture Removed
300675	25-01-2025	10:35:00		Flushed	OT	OT-1B (Rm-1109)	0.00465	No		
300675	25-01-2025	10:40:00		First Draw	BM	BM-4 (Rm-1109)	0.0002	No		
300675	25-01-2025	10:45:00		First Draw	KI	KI-3 (Rm-1109)	0.00049	No		
300675	25-01-2025	10:50:00		First Draw	KC	KC-5A (Rm-1109c)	0.0011	No		
300675	25-01-2025	10:55:00		Flushed	KC	KC-5B (Rm-1109c)	0.00065	No		
300675	25-01-2025	11:00:00		First Draw	BM	BM-5 (1st Floor Hall North)	0.0002	No		
300675	25-01-2025	11:05:00		First Draw	KC	KC-6A (Rm-1109)	0.00081	No		
300675	25-01-2025	11:10:00		Flushed	KC	KC-6B (Rm-1109)	0.00099	No		
300675	25-01-2025	11:15:00		First Draw	KC	KC-7A (Rm-1109)	0.00146	No		
300675	25-01-2025	11:20:00		Flushed	KC	KC-7B (Rm-1109)	0.0002	No		
300675	25-01-2025	11:25:00		First Draw	OT	OT-2A (Rm-1109)	0.00025	No		
300675	25-01-2025	11:30:00		Flushed	OT	OT-2B (Rm-1109)	0.0002	No		
300675	25-01-2025	11:35:00		First Draw	OT	OT-3A (Rm 1109)	0.00038	No		
300675	25-01-2025	11:40:00		Flushed	OT	OT-3B (Rm 1109)	0.00023	No		
300675	25-01-2025	11:45:00		First Draw	OT	OT-4A (Rm 1109)	0.00259	No		
300675	25-01-2025	11:50:00		Flushed	OT	OT-4B (Rm 1109)	0.0003	No		
300675	25-01-2025	11:55:00		First Draw	EC	EC-4A (Rm 1010)	0.00696	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
300675	25-01-2025	12:00:00		Flushed	EC	EC-4B (Rm 1010)	0.00049	No		
300675	23-02-2025	12:05:00		First Draw	EC	EC-4A (Rm 1010)	0.00573	Yes	2A	Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1 min)).
300675	25-01-2025	12:05:00		First Draw	NS	NS-2A (Rm 1005)	0.0179	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
300675	25-01-2025	12:10:00		Flushed	NS	NS-2B (Rm 1005)	0.0011	No		
300675	23-02-2025	12:10:00		First Draw	NS	NS-2A (Rm 1005)	0.00457	No		RE-TEST results
300675	25-01-2025	12:15:00		First Draw	BF	BF-6 (1st floor hall Nlc)	0.0002	No		
300675	25-01-2025	12:20:00		First Draw	KC	KC-8A (Rm1001)	0.00089	No		
300675	25-01-2025	12:25:00		Flushed	KC	KC-8B (Rm 1001)	0.0007	No		
300675	25-01-2025	12:30:00		First Draw	KC	KC-9A (Rm 1000G)	0.0039	No		
300675	25-01-2025	12:35:00		Flushed	KC	KC-9B (Rm 1000G)	0.00064	No		
300675	25-01-2025	12:40:00		First Draw	BM	BM-6 (Rm 1000G)	0.0002	No		
300675	25-01-2025	12:45:00		First Draw	KC	KC-10A (Rm 1202A)	0.00078	No		
300675	25-01-2025	12:50:00		Flushed	KC	KC-10B (Rm 1202A)	0.00024	No		
300675	25-01-2025	12:55:00		First Draw	KC	KC-11A (Rm 1223)	0.00558	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
300675	25-01-2025	13:00:00		Flushed	KC	KC-11B (Rm 1223)	0.0003	No		
300675	23-02-2025	12:15:00		First Draw	KC	KC-11A (Rm 1223)	0.00235	No		RE-TEST results
300675	25-01-2025	13:05:00		First Draw	KC	KC-12A (Rm 1225B)	0.00097	No		
300675	25-01-2025	13:10:00		Flushed	KC	KC-12B (Rm 1225B)	0.00031	No		
300675	25-01-2025	13:15:00		First Draw	KC	KC-13A (Rm 2012)	0.00209	No		
300675	25-01-2025	13:20:00		Flushed	KC	KC-13B (Rm 2012)	0.00023	No		
300675	25-01-2025	13:25:00		First Draw	KC	KC-14A (Lib Office)	0.00052	No		
300675	25-01-2025	13:30:00		Flushed	KC	KC-14B (Lib Office)	0.0003	No		
300675	25-01-2025	13:35:00		First Draw	BF	BF-7 (2nd Floor Hall)	0.0002	No		
300675	25-01-2025	13:40:00		First Draw	BF	BF-8 (2nd Floor weight room)	0.0002	No		
300675	25-01-2025	13:45:00		First Draw	BF	BF-9 (3rd floor Hall)	0.0002	No		
300675	25-01-2025	13:50:00		First Draw	BF	BF-10 (3rd floor Hall)	0.0002	No		
300675	25-01-2025	13:55:00		First Draw	BF	BF-11 (3rd floor Hall)	0.0002	No		
300675	25-01-2025	14:00:00		First Draw	KC	KC-15A (3rd floor staff rm)	0.0011	No		
300675	25-01-2025	14:05:00		Flushed	KC	KC-15B (3rd Floor staff rm)	0.00028	No		
300675	25-01-2025	14:10:00		First Draw	BM	BM-7 (3rd Floor Staff rm)	0.00075	No		
300675	25-01-2025	14:15:00		First Draw	KI	KI-4 (3rd Floor Staff rm)	0.00084	No		
East Chilliwack EI										
102002	26-01-2025	11:00:00		First Draw	KC	KC-1A (Rm 1)	0.00236	No		
102002	26-01-2025	11:05:00		Flushed	KC	KC-1B (Rm-1)	0.00031	No		
102002	26-01-2025	11:10:00		First Draw	BF	BF-1 (North Hall/gym)	0.0002	No		
102002	26-01-2025	11:15:00		First Draw	KC	KC-KIT A (Rm-32)	0.00118	No		
102002	26-01-2025	11:20:00		Flushed	KC	KC-KIT B (Rm-32)	0.00331	No		
102002	26-01-2025	11:25:00		First Draw	NS	NS-1A (First Aid Rm)	0.0318	Yes	3C	Signage posted (Restricted use - Handwash Only)
102002	26-01-2025	11:30:00		Flushed	NS	NS-1B (First Aid Rm)	0.00112	No		
102002	26-01-2025	11:35:00		First Draw	KC	KC-5A (Rm-5A)	0.0111	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
102002	26-01-2025	11:40:00		Flushed	KC	KC-5B (Rm-5A)	0.00083	No		
102002	23-02-2025	10:00:00		First Draw	KC	KC-5A (Rm-5A)	0.0047	No		RE-TEST results
102002	26-01-2025	11:45:00		First Draw	BF	BF-2 (West Hall)	0.0002	No		
102002	26-01-2025	11:50:00		First Draw	KC	KC-17A (Staff Rm)	0.00052	No		

102002	26-01-2025	11:55:00	Flushed	KC	KC-17B (Staff Rm)	0.00056	No		
102002	26-01-2025	12:00:00	First Draw	KC	KC-11B A (Rm-27)	0.0159	Yes	3C	Signage posted (Restricted use - Handwash Only)
102002	26-01-2025	12:05:00	Flushed	KC	KC-11B B (Rm-27)	0.00261	No		
102002	26-01-2025	12:10:00	First Draw	BF	BF-3 (South East hall)	0.0002	No		
F.G. Leary El									
102077	26-01-2025	13:00:00	First Draw	BF	BF-1 (North Gym Hall)	0.0002	No		
102077	26-01-2025	13:05:00	First Draw	KC	KC-STAFF-A (Rm-38)	0.00632	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
102077	26-01-2025	13:10:00	Flushed	KC	KC-STAFF-B (Rm-38)	0.00065	No		
102077	23-02-2025	09:00:00	First Draw	KC	KC-STAFF-A (Rm-38)	0.00002	No		RE-TEST results
102077	26-01-2025	13:15:00	First Draw	KC	KC-1E-A (1E Rm)	0.0045	No		
102077	26-01-2025	13:20:00	Flushed	KC	KC-1E-B (1E Rm)	0.00271	No		
102077	26-01-2025	13:25:00	First Draw	KC	KC-L1B-A (Rm-109A)	0.00227	No		
102077	26-01-2025	13:30:00	Flushed	KC	KC-L1B-B (Rm-109A)	0.0002	No		
102077	26-01-2025	13:35:00	First Draw	BF	BF-2 (East Hall)	0.0002	No		
102077	26-01-2025	13:40:00	First Draw	BF	BF-3 (South Hall)	0.0002	No		
102077	26-01-2025	13:45:00	First Draw	KC	KC-12A (Rm-12)	0.00033	No		
102077	26-01-2025	13:50:00	Flushed	KC	KC-12B (Rm-12)	0.0002	No		
102077	26-01-2025	13:55:00	First Draw	NS	NS-1A (Health Rm)	0.00131	No		
102077	26-01-2025	14:00:00	Flushed	NS	NS-1B (Health Rm)	0.00066	No		
Rosedale Traditional									
300494	26-01-2025	07:00:00	First Draw	KC	KC-DAY-1A (Rm 136A)	0.00086	No		
300494	26-01-2025	07:05:00	Flushed	KC	KC-DAY-1B (Rm 136A)	0.00071	No		
300494	26-01-2025	07:10:00	First Draw	KC	KC-DAY-2A (Rm 122)	0.00042	No		
300494	26-01-2025	07:15:00	Flushed	KC	KC-DAY-2B (Rm 122)	0.0002	No		
300494	26-01-2025	07:20:00	First Draw	KC	KC-120-1A (Rm-120 West)	0.00195	No		
300494	26-01-2025	07:25:00	Flushed	KC	KC-120-1B (Rm-120 West)	0.00068	No		
300494	26-01-2025	07:30:00	First Draw	KC	KC-120-2A (Rm-120 East)	0.00118	No		
300494	26-01-2025	07:35:00	Flushed	KC	KC-120-2B (Rm-120 East)	0.00048	No		
300494	26-01-2025	07:40:00	First Draw	KC	KC-160-1A (Kitchen Multi Purpose West)	0.00072	No		
300494	26-01-2025	07:45:00	Flushed	KC	KC-160-1B (Kitchen Multi Purpose West)	0.0002	No		
300494	26-01-2025	07:50:00	First Draw	KC	KC-160-2A (Kitchen Multi Purpose East)	0.0013	No		
300494	26-01-2025	07:55:00	Flushed	KC	KC-160-2B (Kitchen Multi Purpose East)	0.00074	No		
300494	26-01-2025	08:00:00	First Draw	DW	DW-1 (Gym Corridor South)	0.00056	No		
300494	26-01-2025	08:05:00	First Draw	BF	BF-1 (South Hall Gym)	0.0002	No		
300494	26-01-2025	08:10:00	First Draw	EC	EC-1-1A (Rm-143)	0.00133	No		
300494	26-01-2025	08:15:00	Flushed	EC	EC-1-1B (Rm-143)	0.00022	No		
300494	26-01-2025	08:20:00	First Draw	EC	EC-1-2A (Rm-143)	0.00085	No		
300494	26-01-2025	08:25:00	Flushed	EC	EC-1-2B (Rm-143)	0.0002	No		
300494	26-01-2025	08:30:00	First Draw	EC	EC-1-3A (Rm-143)	0.00036	No		
300494	26-01-2025	08:35:00	Flushed	EC	EC-1-3B (Rm-143)	0.0002	No		
300494	26-01-2025	08:40:00	First Draw	EC	EC-1-4A (Rm-143)	0.00034	No		
300494	26-01-2025	08:45:00	Flushed	EC	EC-1-4B (Rm-143)	0.00251	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
300494	23-02-2025	11:10:00	First Draw	EC	EC-1-4A (Rm-143)	0.00083	No		RE-TEST results
300494	26-01-2025	08:50:00	First Draw	EC	EC-1-5A (Rm-143)	0.00055	No		
300494	26-01-2025	08:55:00	Flushed	EC	EC-1-5B (Rm-143)	0.00352	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
300494	23-02-2025	11:15:00	First Draw	EC	EC-1-5A (Rm-143)	0.00118	No		RE-TEST results
300494	26-01-2025	09:00:00	First Draw	EC	EC-1-6A (Rm-143)	0.00094	No		
300494	26-01-2025	09:05:00	Flushed	EC	EC-1-6B (Rm-143)	0.0002	No		
300494	26-01-2025	09:10:00	First Draw	EC	EC-1-7A (Rm-143)	0.00053	No		
300494	26-01-2025	09:15:00	Flushed	EC	EC-1-7B (Rm-143)	0.00025	No		
300494	26-01-2025	09:20:00	First Draw	KC	KC-111A (Rm-111)	0.00044	No		
300494	26-01-2025	09:25:00	Flushed	KC	KC-111B (Rm-111)	0.00027	No		
300494	26-01-2025	09:30:00	First Draw	KC	KC-110A (Lib Office)	0.0018	No		
300494	26-01-2025	09:35:00	Flushed	KC	KC-110B (Lib Office)	0.00061	No		
300494	26-01-2025	09:40:00	First Draw	KC	KC-104A (Staff Rm)	0.00086	No		
300494	26-01-2025	09:45:00	Flushed	KC	KC-104B (Staff Rm)	0.00035	No		
300494	26-01-2025	09:50:00	First Draw	NS	NS-1A (Health Rm)	0.00094	No		
300494	26-01-2025	09:55:00	Flushed	NS	NS-1B (Health Rm)	0.00056	No		
300494	26-01-2025	10:00:00	First Draw	KC	KC-305B-A (Rm-305)	0.00752	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
300494	26-01-2025	10:05:00	Flushed	KC	KC-305B-B (Rm-305)	0.00039	No		
300494	23-02-2025	11:00:00	First Draw	KC	KC-305B-A (Rm-305)	0.00151	No		RE-TEST results
300494	26-01-2025	10:10:00	First Draw	KC	KC-309B-A (Rm-309)	0.00499	No		
300494	26-01-2025	10:15:00	Flushed	KC	KC-309B-B (Rm-309)	0.00394	No		
300494	26-01-2025	10:20:00	First Draw	BF	BF-2 (North Hall)	0.0002	No		
300494	26-01-2025	10:25:00	First Draw	KC	KC-409A-1A (Rm 409A-west)	0.00714	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
300494	26-01-2025	10:30:00	Flushed	KC	KC-409A-1B (Rm 409A-west)	0.00453	No		
300494	23-02-2025	10:05:00	First Draw	KC	KC-409A-1A (Rm 409A-west)	0.0115	Yes	2A	Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1 min)).
300494	26-01-2025	10:35:00	First Draw	KC	KC-409A-2A (Rm 409A-East)	0.00281	No		
300494	26-01-2025	10:40:00	Flushed	KC	KC-409A-2B (Rm 409A-East)	0.00037	No		
300494	26-01-2025	10:45:00	First Draw	BF	BF-3 (2nd Floor Hall)	0.0002	No		
Sardis Elementary									
101975	09-02-2025	11:00:00	First Draw	KC	KC 1A (Staff Rm 32)	0.00141	No		
101975	09-02-2025	11:05:00	Flushed	KC	KC 1B (Staff Rm 32)	0.0002	No		
101975	09-02-2025	11:10:00	First Draw	NS	NS 1A (Health Rm)	0.0367	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
101975	09-02-2025	11:15:00	Flushed	NS	NS 1B (Health Rm)	0.00176	No		
101975	23-02-2025	07:00:00	First Draw	NS	NS 1A (Health Rm)	0.00095	No		RE-TEST results
101975	09-02-2025	11:20:00	First Draw	KC	KC 2A (Rm-45)	0.00299	No		
101975	09-02-2025	11:25:00	Flushed	KC	KC 2B (Rm-45)	0.00032	No		
101975	09-02-2025	11:30:00	First Draw	BF	BF 1 (East/gym Hall)	0.0002	No		
101975	09-02-2025	11:35:00	First Draw	DW	DW 1 (Gym foyer)	0.00056	No		
101975	09-02-2025	11:40:00	First Draw	BF	BF 2 (North Hall)	0.0002	No		
101975	09-02-2025	11:45:00	First Draw	BF	BF 3 (South Hall)	0.0002	No		
101975	09-02-2025	11:50:00	First Draw	KC	KC 3A (Kindergarten kit)	0.0004	No		
101975	09-02-2025	11:55:00	Flushed	KC	KC 3B (Kindergarten kit)	0.00307	No		
101975	09-02-2025	12:00:00	First Draw	KC	KC 4A (Lib Office)	0.203	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
101975	09-02-2025	12:05:00	Flushed	KC	KC 4B (Lib Office)	0.00035	No		
101975	23-02-2025	07:05:00	First Draw	KC	KC 4A (Lib Office)	0.00414	No		RE-TEST results
101975	09-02-2025	12:10:00	First Draw	KC	KC 5A (Modular biding)	0.00396	No		
101975	09-02-2025	12:15:00	Flushed	KC	KC 5B (Modular biding)	0.00068	No		
Strathcona									
101966	17-02-2025	10:00:00	First Draw	NS	NS 1A (Health Rm)	0.00058	No		
101966	17-02-2025	10:05:00	Flushed	NS	NS 1B (Health Rm)	0.00066	No		
101966	17-02-2025	10:10:00	First Draw	KC	KC Staff A (Rm-110)	0.00188	No		
101966	17-02-2025	10:15:00	Flushed	KC	KC Staff B (Rm-110)	0.00056	No		
101966	17-02-2025	10:20:00	First Draw	KC	KC 161A (Rm-161A)	0.00166	No		
101966	17-02-2025	10:25:00	Flushed	KC	KC 161B (Rm-161A)	0.00117	No		
101966	17-02-2025	10:30:00	First Draw	BF	BF 1 (East Hall)	0.0002	No		
101966	17-02-2025	10:35:00	First Draw	KC	KC 155A (Rm-155)	0.0007	No		
101966	17-02-2025	10:40:00	Flushed	KC	KC 155B (Rm-155)	0.00255	No		
101966	17-02-2025	10:45:00	First Draw	BF	BF 2 (Gym Hall Lobby)	0.0002	No		
101966	17-02-2025	10:50:00	First Draw	KC	KC149A-A (Rm-149 Kitchen)	0.00074	No		
101966	17-02-2025	10:55:00	Flushed	KC	KC149A-B (Rm-149 Kitchen)	0.00027	No		
101966	17-02-2025	11:00:00	First Draw	BF	BF 3 (North Hall)	0.0002	No		
101966	17-02-2025	11:05:00	First Draw	KC	KC 134A (Rm-134)	0.00901	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
101966	17-02-2025	11:10:00	Flushed	KC	KC 134B (Rm-134)	0.00054	No		
101966	20-03-2025	08:00:00	First Draw	KC	KC 134A (Rm-134)	0.00173	No		RE-TEST results
101966	17-02-2025	11:15:00	First Draw	BF	BF 4 (West Hall)	0.0002	No		
101966	17-02-2025	11:20:00	First Draw	KC	KC Hall-A (Kindergarten kit)	0.0102	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
101966	17-02-2025	11:25:00	Flushed	KC	KC Hall-B (Kindergarten kit)	0.0005	No		

101966	20-03-2025	08:05:00		First Draw	KC	KC Hall-A (Kindergarten kit)	0.0028	No		RE-TEST results
Bernard										
102044	17-02-2025	07:00:00		First Draw	BF	BF 1 (North Hall)	0.0002	No		
102044	17-02-2025	07:05:00		First Draw	KC	KC 6A (Rm-6)	0.023	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
102044	17-02-2025	07:10:00		Flushed	KC	KC 6B (Rm-6)	0.0005	No		
102044	20-03-2025	09:00:00		First Draw	KC	KC 6A (Rm-6)	0.00191	No		RE-TEST results
102044	17-02-2025	07:15:00		First Draw	KC	KC PACA (Rm-41)	0.00123	No		
102044	17-02-2025	07:20:00		Flushed	KC	KC PACB (Rm-41)	0.00047	No		
102044	17-02-2025	07:25:00		First Draw	KC	KC LIB-A (Rm-16)	0.0956	Yes	3C	Signage posted (Restricted use - Handwash Only)
102044	17-02-2025	07:30:00		Flushed	KC	KC LIB-B (Rm-16)	0.00101	No		
102044	17-02-2025	07:35:00		First Draw	KC	KC Staff-A (Staff Rm-19)	0.0116	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
102044	17-02-2025	07:40:00		Flushed	KC	KC Staff-B (Staff Rm-19)	0.0002	No		
102044	20-03-2025	09:05:00		First Draw	KC	KC Staff-A (Staff Rm-19)	0.00228	No		RE-TEST results
102044	17-02-2025	07:45:00		First Draw	BF	BF 2 (East Hall)	0.0002	No		
102044	17-02-2025	07:50:00		First Draw	BF	BF 3 (South Hall)	0.0002	No		
102044	17-02-2025	07:55:00		First Draw	KC	KC 30A (Rm-30)	0.00143	No		
102044	17-02-2025	08:00:00		Flushed	KC	KC 30B (Rm-30)	0.0002	No		
102044	17-02-2025	08:05:00		First Draw	KC	KC WetA (Portable)	0.00304	No		
102044	17-02-2025	08:10:00		Flushed	KC	KC WetB (Portable)	0.00072	No		
Greendale										
121039	16-02-2025	10:00:00		First Draw	KC	KC Staff-A	0.00282	No		
121039	16-02-2025	10:05:00		Flushed	KC	KC Staff-B	0.0002	No		
121039	16-02-2025	10:10:00		First Draw	BF	BF 1 (Hall)	0.0002	No		
121039	16-02-2025	10:15:00		First Draw	KC	KC 17 (Rm-17)	0.00057	No		
121039	16-02-2025	10:20:00		First Draw	DW	DW 1 (Rm-17)	0.0002	No		
121039	16-02-2025	10:25:00		First Draw	NS	NS 1A (Health Rm)	0.00116	No		
121039	16-02-2025	10:30:00		Flushed	NS	NS 1B (Health Rm)	0.0002	No		
121039	16-02-2025	10:35:00		First Draw	KC	KC MPA (Hall Multi Pur)	0.00281	No		
121039	16-02-2025	10:40:00		Flushed	KC	KC MPB (Hall Multi Pur)	0.00191	No		
Promontory										
112280	17-02-2025	12:00:00		First Draw	KC	KC Staff-A (Staff Rm)	0.00035	No		
112280	17-02-2025	12:05:00		Flushed	KC	KC Staff-B (Staff Rm)	0.00065	No		
112280	17-02-2025	12:10:00		First Draw	BF	BF 1 (South Hall Gym)	0.0002	No		
112280	17-02-2025	12:15:00		First Draw	KC	KC 120-A (Rm-120)	0.00049	No		
112280	17-02-2025	12:20:00		Flushed	KC	KC 120-B (Rm-120)	0.00052	No		
112280	17-02-2025	12:25:00		First Draw	KC	KC 206-A (Rm-206)	0.0002	No		
112280	17-02-2025	12:30:00		Flushed	KC	KC 206-B (Rm-206)	0.0005	No		
112280	17-02-2025	12:35:00		First Draw	KC	KC 226-A (Rm-226)	0.0002	No		
112280	17-02-2025	12:40:00		Flushed	KC	KC 226-B (Rm-226)	0.00046	No		
112280	17-02-2025	12:45:00		First Draw	BF	BF 2 (2nd Floor Hall)	0.0002	No		
112280	17-02-2025	12:50:00		First Draw	KC	KC 222-A (Rm-222)	0.0002	No		
112280	17-02-2025	12:55:00		Flushed	KC	KC 222-B (Rm-222)	0.00053	No		
112280	17-02-2025	13:00:00		First Draw	KC	KC 140-A (Rm-140)	0.00025	No		
112280	17-02-2025	13:05:00		Flushed	KC	KC 140-B (Rm-140)	0.0005	No		
112280	17-02-2025	13:10:00		First Draw	BF	BF 3 (North Hall)	0.0002	No		
112280	17-02-2025	13:15:00		First Draw	BF	BF 4 (East Hall Multi purpose)	0.0002	No		
Tyson Elementary										
102084	16-02-2025	07:00:00		First Draw	BF	BF 1 (West Hall Gym)	0.0002	No		
102084	16-02-2025	07:05:00		First Draw	NS	NS 1A (Health Rm)	0.00092	No		
102084	16-02-2025	07:10:00		Flushed	NS	NS 1B (Health Rm)	0.00106	No		
102084	16-02-2025	07:15:00		First Draw	KC	KC 1A (Staff Rm)	0.00313	No		
102084	16-02-2025	07:20:00		Flushed	KC	KC 1B (Staff Rm)	0.00219	No		
102084	16-02-2025	07:25:00		First Draw	KC	KC 2A (Lib Stor)	0.00147	No		
102084	16-02-2025	07:30:00		Flushed	KC	KC 2B (Lib Stor)	0.00091	No		
102084	16-02-2025	07:35:00		First Draw	BF	BF 2 (East Hall)	0.0002	No		
102084	16-02-2025	07:40:00		First Draw	KC	KC 3A (Modular Portable)	0.00753	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
102084	16-02-2025	07:45:00		Flushed	KC	KC 3B (Modular Portable)	0.00108	No		
102084	26-03-2025	08:00:00		First Draw	KC	KC 3A (Modular Portable)	0.004	No		RE-TEST results
102084	16-02-2025	07:50:00		First Draw	KC	KC 4A (Portable)	0.00621	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
102084	16-02-2025	07:55:00		Flushed	KC	KC 4B (Portable)	0.00034	No		
102084	26-03-2025	08:05:00		First Draw	KC	KC 4A (Portable)	0.00271	No		RE-TEST results
Yarrow Elementary										
300676	16-02-2025	08:00:00		First Draw	KC	KC 118A (Rm-118)	0.00089	No		
300676	16-02-2025	08:05:00		Flushed	KC	KC 118B (Rm-118)	0.0007	No		
300676	16-02-2025	08:10:00		First Draw	KC	KC 114A (Rm-114)	0.0008	No		
300676	16-02-2025	08:15:00		Flushed	KC	KC 114B (Rm-114)	0.00077	No		
300676	16-02-2025	08:20:00		First Draw	KC	KC 108A (Rm-108)	0.00199	No		
300676	16-02-2025	08:25:00		Flushed	KC	KC 108B (Rm-108)	0.00076	No		
300676	16-02-2025	08:30:00		First Draw	BF	BF 1 (North Corridor)	0.0002	No		
300676	16-02-2025	08:35:00		First Draw	KC	KC 107A (Rm-107)	0.00347	No		
300676	16-02-2025	08:40:00		Flushed	KC	KC 107B (Rm-107)	0.00067	No		
300676	16-02-2025	08:45:00		First Draw	KC	KC 107 PrepA (Rm-107)	0.0014	No		
300676	16-02-2025	08:50:00		Flushed	KC	KC 107 PrepB (Rm-107)	0.00087	No		
300676	16-02-2025	08:55:00		First Draw	KC	KC StaffA (Staff Rm)	0.00317	No		
300676	16-02-2025	09:00:00		Flushed	KC	KC StaffB (Staff Rm)	0.00165	No		
300676	16-02-2025	09:05:00		First Draw	KC	KC 303B-A (Rm-303B)	0.00096	No		
300676	16-02-2025	09:10:00		Flushed	KC	KC 303B-B (Rm-303B)	0.00084	No		
300676	16-02-2025	09:15:00		First Draw	BF	BF 2 (South Corridor)	0.00027	No		
300676	16-02-2025	09:20:00		First Draw	KC	KC 309B-A (Rm-309B)	0.00203	No		
300676	16-02-2025	09:25:00		Flushed	KC	KC 309B-B (Rm-309B)	0.00092	No		
300676	16-02-2025	09:30:00		First Draw	BF	BF 3 (2nd Floor Corridor)	0.00026	No		
Vedder Elementary										
102006	16-02-2025	14:00:00		First Draw	BF	BF 4 (2nd Floor hall)	0.0002	No		
102006	16-02-2025	14:05:00		First Draw	BF	BF 3 (West Hall)	0.0002	No		
102006	16-02-2025	14:10:00		First Draw	KC	KC 187A (Rm-187)	0.00195	No		
102006	16-02-2025	14:15:00		Flushed	KC	KC 187B (Rm-187)	0.00024	No		
102006	16-02-2025	14:20:00		First Draw	KC	KC North A (Rm-154 Hall)	0.00044	No		
102006	16-02-2025	14:25:00		Flushed	KC	KC North B (Rm-154 Hall)	0.0002	No		
102006	16-02-2025	14:30:00		Flushed	KC	KC East B (Rm-154 Hall)	0.00261	No		
102006	16-02-2025	14:35:00		First Draw	KC	KC East A (Rm-154 Hall)	0.0139	Yes	2A	Temporary Signage Posted near the fixture to run the water prior to use. (until water runs Cold (1-5 min)). Faucet and Supply lines to be replaced. Retest fixture following replacement.
102006	23-02-2025	08:00:00		First Draw	KC	KC East A (Rm-154 Hall)	0.00072	No		RE-TEST results
102006	16-02-2025	14:40:00		First Draw	BF	BF 2 (Center Hall)	0.0002	No		
102006	16-02-2025	14:45:00		First Draw	KC	KC 121A (Rm-121)	0.00551	Yes	3C	Signage posted (Restricted use - Handwash Only)
102006	16-02-2025	14:50:00		Flushed	KC	KC 121B (Rm-121)	0.00599	Yes	3C	Signage posted (Restricted use - Handwash Only)
102006	16-02-2025	14:55:00		First Draw	KC	KC LIBA (Library office)	0.129	Yes	3C	Signage posted (Restricted use - Handwash Only)
102006	16-02-2025	15:00:00		Flushed	KC	KC LIB B (Library office)	0.00076	No		
102006	16-02-2025	15:05:00		First Draw	KC	KC 110 - A (Rm-110)	0.00118	No		
102006	16-02-2025	15:10:00		Flushed	KC	KC 110 - B (Rm-110)	0.00027	No		
102006	16-02-2025	15:15:00		First Draw	KC	KC Staff-A (Staff Rm)	0.00183	No		
102006	16-02-2025	15:20:00		Flushed	KC	KC Staff-B (Staff Rm)	0.00021	No		
102006	16-02-2025	15:25:00		First Draw	BF	BF 1 (East Hall Gym)	0.0002	No		